

**Class 1 Permit Modification Notice**  
**Hazardous Waste Management Facilities**  
**EPA ID No. 2890012584-Livermore Site**  
**Lawrence Livermore National Laboratory**

This notice is issued within 90 days of a class 1 modification implementation in accordance with the Title 22 CCR. Lawrence Livermore National Laboratory notified the Department of Toxic Substances Control (DTSC) of a class 1 modification to its hazardous waste management facility in a letter dated February 24, 2003. The DTSC approved the change in a letter dated July 29, 2003. As stated in Title 22 CCR Section 66270.42(d)(2)(A) "Class 1 modifications apply to minor changes that keep the permit current with routine changes to the facility or its operations. These changes do not substantially alter the permit conditions or reduce the capacity of the facility to protect human health or the environment."

The Class 1 modification implemented consisted of replacing the dry chemical fire suppression system in the Decontamination and Waste Treatment Facility (DWTF) Reactive Waste Processing Area with a wet pipe sprinkler system. This change improves the fire suppression system in the area.

Questions regarding this modification may be addressed to the following DTSC or LLNL representatives.

Mr. Micheal Stanek  
Department of Toxic Substances Control  
8800 Cal Center Drive  
Sacramento, CA 95826-3200  
Tel. (916) 255-6699  
e-mail [mstanek@dtsc.ca.gov](mailto:mstanek@dtsc.ca.gov)

Ms. Lora Barrett  
Department of Toxic Substances Control  
8800 Cal Center Drive  
Sacramento, CA 95826-3200  
Tel. (916) 255-6681  
e-mail [lbarrett@dtsc.ca.gov](mailto:lbarrett@dtsc.ca.gov)

Mr. Bert Heffner  
Lawrence Livermore National Laboratory (LLNL)  
P.O. Box 808, L-404  
Livermore, CA 94551  
Tel. (925) 424-4026  
e-mail [heffner1@llnl.gov](mailto:heffner1@llnl.gov)